

Borough of Westwood
APPLICATION FOR CURB, SIDEWALK and CONCRETE
DRIVEWAY APRON REPLACEMENT

Date Application received _____
For Borough Use Only

1. Applicant: Name _____
Address _____
Telephone Number _____
2. Location: Block _____ Lot _____ (Use current Tax Assessment Maps in Borough Hall)
3. Property Owner (if different from the Applicant):
Name _____
Address _____
Telephone Number _____
4. Structure(s) to be replaced:
- | | |
|---|-------------------------------|
| _____ Curb | Approximate Linear Feet _____ |
| _____ Drop Curb | Approximate Linear Feet _____ |
| _____ Sidewalk | Approximate Square Feet _____ |
| _____ Driveway Apron | Approximate Square Feet _____ |
| _____ Other (specify kind and quantity) _____ | |
5. Trees:
Are trees located near any structure to be replaced? (yes/no)
Will trees and/or their root systems be affected by this work? (yes/no)
- At no time shall a homeowner or contractor remove any trees or roots without an inspection by the Department of Public Works.
6. On what date will proposed work commence? _____

Please contact the Borough of Westwood's Department of Public Works, 48 hours in advance, to schedule an inspection prior to the pouring of the concrete. The Department of Public Works number is 201-664-2349.

Property Owner's Signature & Date

Applicant's Signature & Date
(if different from the property owner)

Construction specifications are located on the back of this Application.

Construction Specifications:

Curbs:

- a. Curbs shall be concrete NJDOT Class "B" (air entrained).
- b. Curbs shall be 9 inches by 20 inches with a maximum curb section of twenty (20') feet, and a scored joint every ten (10') feet.
- c. Curbing shall be designed to provide a curb ramp in compliance with the Americans with Disabilities Act or the Barrier Free subcode of the New Jersey Uniform Construction Code (N.J.A.C. 5:23-7) at street intersections, as applicable.

Sidewalks/Driveway Aprons:

- a. Sidewalks/Driveway Aprons shall be concrete Class "C" (air entrained), having a 28-day verification strength of 4,000 p.s.i.
- b. Sidewalks shall be four (4") inches thick except at points of vehicular crossings, where they should be at least six (6") inches thick. At vehicular crossings, concrete sidewalks/driveway aprons shall be reinforced with welded wire fabric mesh or an equivalent.
- c. Sidewalk width shall be four (4') feet; wider widths may be necessary near pedestrian generators and employment centers.
- d. Graded areas shall be planted with grass or treated with other suitable ground cover, and their width and cross slope shall correspond to that of sidewalks.